

Tarrant Appraisal District Network Cabling Request for Proposals vendor question list 1.

Below is a list of vendor questions in black text followed by TAD's responses in red text.

1. Is there currently any type of J-Hooks or Raceway for cable support?
No
2. Is there a preferred color of cable, wall plates or Inserts?
Network Cable Color:
CANNOT be white or blue
All new cable provided by the vendor must be the same color.
Wall Plates and Inserts Color:
Wall plates and inserts are to match in color and match the color of the light switches and electrical outlets in the room.
3. Does the NEW 4 post Server Rack need to be lockable and fully enclosed?
NO, this should be an open rack
4. Is there a Brand Preference of Inserts, Cables, Patch Panels or Racks?
Inserts, Cables, and Patch Panels must be established brands in the industry which are of good standing and known to provide quality products.
The Rack may be of any brand.
5. Is the entire building LIFT OUT Ceiling? **YES.**
6. For the Cubicle locations, is there currently Power Poles there for the Network cabling? **YES**
7. Are the Voice and Data cables going to be separated? **NO.**
8. Is above the ceiling insulated? **There is no insulation on the back of the ceiling tiles the insulation is on the back of the roof decking and will not be disturbed by project.**
9. Are you a taxable entity? **NO**
10. What size is the new room, where the racks are going and where on the print are the racks going? **The location is shown on the building layout with the star labeled "Patch Panel Location" this is in a 27X45 server room with server racks in the vicinity of the location for the new four post rack that will hold the new patch panels.**